

14. Periodical flashing of water in the Hydrants & Sprinkler Pipe line shall be made to maintain the efficient working performance of above mention system.

15. The Fire Safety audit to be conducted at regular interval and to be recorded ID the Fire Prevention maintenance registers.

16. Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this fire safety certificate will be treated as cancelled

17. This 'Fire Safety Certificate' is valid for three years only from the date of issue subject to the maintenance of Fire Fighting System so installed in proper order.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by ASHISH
KUMAR PUTA BUNDA
Date: 2025.06.24 11:25:00 IST

Chandra K. Landa

PRESIDENT
MANAGING COMMITTEE
Green Shield Academy
TAKDAH CANTT. Darjeeling

R. Pradhan
Principal
GREEN-SHIELD ACADEMY
TAKDAH CANTT.
DARJEELING - 734222